



This document has been prepared to provide some guidance on the activities that a contractor is allowed to perform under each category of registration. The list of activities for each category of registration is intended to provide a general idea and contractors are not necessarily limited to only the activities list here. If you have questions about activities that are not listed, you may contact the Residential Sewage Program for additional guidance at 614-644-7551.

Installer – activity of installing, or altering STS or GWRS [OAC 3701-29-01 (FFF)]	Service Provider – activity of servicing, monitoring, evaluating or sampling STS or GWRS [OAC 3701-29-01 (OOOO)]	Septage Hauler – collection, transportation, disposal and/or land application of domestic septage, and evaluate and report on the condition of the tank(s) they are pumping. [OAC 3701-29-01 (JJJJ)]
Installation or alteration work in accordance with a valid installation/permit issued by the board of health	Routine service and maintenance required for product approval and/or operation permit (e.g. service contracts) for STS or GWRS, including in-place correction, cleaning, or replacement of damaged or worn out devices with approved devices	Evaluate and report on: <ul style="list-style-type: none"> • condition of the tank • presence/absence of baffles or tees • conditions of risers • evidence of high water or water intrusion • tank deterioration
Inspection for trouble-shooting STS issues if installed or altered by same installer	Replacement of mechanical devices (agitators, compressors, and pumps), and broken, worn-out, or damaged parts	Conduct and report any minor repairs limited to structure of the tank(s) being pumped, including: <ul style="list-style-type: none"> • Installation/replacement of lids or risers on the tank • Installation, repair, or replacement of tank baffles • Installation, cleaning, or repair of effluent filter at outlet of tank
Installation or replacement of lids, risers, distribution boxes, drop boxes, tank baffles, effluent filters, etc.	Replacement or cleaning of STS filter media	
Installation of sampling ports	Installation of sampling ports	Maintain records and manifest of septage or sewage pumped from each STS as required in OAC 3701-29-20 (C).
	Installation or replacement lids, risers, baffles	
	Installation or cleaning of outlet filters	
	Monitoring of STS or component for verification of performance requirements, including dye tests	
	Evaluation of STS (i.e. real estate/point-of-sale inspections)	
	Sample collection from STS for lab analysis	